

copy



IO175
DСТU EN ISO/IEC 17065



ЦСМБ
CCM&G

СЕРТИФІКАТ ВІДПОВІДНОСТІ

СЕРТИФИКАТ СООТВЕТСТВИЯ/ CERTIFICATE ON CONFORMITY

Зареєстровано в реєстрі органу сертифікації за №

UA.032.CC.0111-21

Зарегистрирован в реестре органа сертификации под №/
Registered at the Record of certification body under №

Термін дії з

19 April 2021 up to 18 April 2024

Срок действия с/
Term of validity is from

Сертифікат
видано

«KOVLAR GROUP» LLC,
04116, Kiev, st. Starokyivska, 10-G, EDRPOU 39875591

Сертифікат выдан/
Certificate is issued on

Продукція

Fireproofing coating (paint with reactive property) «Ammokote MF-180»
for fire protection of cables and cable lines

20.30.22

Продукция/Production

(код (s) УКТЗЕД/ДКПП
(UKTZED/DKPP code (s)))

(повна назва, тип, вид, марка, торгова марка) / (complete product name, type, kind, model, merchandise mark (trademark))

DBN B.2.5-23:2010 «Engineering equipment of buildings and structures. Design of equipment for civil purposes» item 4.36 (д);

Відповідає
вимогам

NAPB B.01.014-2007 «Fire safety rules for the operation of nuclear power plants» items 7.2.4.20, 7.2.4.21;
DSTU 4809:2007 «Insulated wires and cables. Fire safety requirements and test methods» item 4.2,
on resistance to flame propagation (non-combustion) by wires and cables laid in bundles of
category A F / R (according to DSTU EN 60332-3-21:2013) subject to the application of fireproofing
coating with an average dry film thickness of 0.49 mm and with an average consumption of
0.90 kg / m² (excluding technological losses)

Соответствует требованиям/
Comply with the requirements

(позначення нормативних документів)/(denotation of normative documents)

Виробник

«KOVLAR GROUP» LLC,
04116, Kiev, st. Starokyivska, 10-G, EDRPOU 39875591

Производитель/
Producer

Місце

08606, Kyiv region, Vasylykiv, street Perforated, 4.
03151, Kyiv, street Volynska, 65

виробництва
Место производства/
Place of production

Сертифікат
видано органом
сертифікації

CB «Center certification of materials and goods»,
legal address: 03164, Kyiv, street Malinska, 20-A;
fact. address: 03067, Kyiv, street O. Tikhogo, 103;
tel. 221-94-10; 404-88-03; 457-69-23

Сертифікат выдан органом
сертификации/
Certificate is issued by the
certification body

Додаткова
інформація

Products mass-produced from 19.04.2021 to 18.04.2024 for TY У 20.3-39875591-001:2015
«Fireproofing coatings Ammokote» with changes №№ 1, 2, 3, 4, 5.

Дополнительная
информация/Additional
information

Inspection control over the production of certified products during the validity of the certificate of
conformity in accordance with the License Agreement

На підставі

Test report dated 25.06.2019 № 57 / 2-2019 Research Center «Fire Safety» Institute of Public
Administration and Research in Civil Protection (accreditation certificate № 20278).

На основании/
On the grounds of

Report on the inspection of internal control of production from 14.04.2021 № 087/21 CB «CCMG».
Decision № 094/21 of 16.04.2021 on the issuance of a certificate of conformity CB «CCMG»

Deputy head of the certification body

Руководитель органа сертификации/
Director of the certification body



V. Priymachenko

(підпис, ініціали, прізвище)
(signature, initials, family name)